

Eugene School District 4J  
Water Quality: Lead Testing Results

Eugene School District 4J - Location	Fixture Type	First Draw			Flushed Draw			New Fixture First Draw				Follow Up - New Fixture Draw			
		Date Sampled	Sample ID #	Result (ppb)	Date Sampled	Sample ID #	Result (ppb)	Fixture Replaced	Date Sampled	Sample ID #	Result (ppb)	Additional Action	Date Sampled	Sample ID #	Result (ppb)
Adams Elementary School															
Office West Wall	Sink	6/30/2016	ADES-I-001	9.16											
Office West Wall	Insta-Hot	6/30/2016	ADES-I-002	0.51											
Office Rest Room	Sink	6/30/2016	ADES-I-003	1.22											
Nurses Office	Sink	6/30/2016	ADES-I-004	3.41											
Nurses Office Rest Room	Sink	6/30/2016	ADES-I-005	1.01											
Kitchen Produce (Left)	Sink	6/30/2016	ADES-I-006	0.56											
Kitchen Produce (Right)	Sink	6/30/2016	ADES-I-007	5.50											
Across from Multi-Purpose Room	Fountain	6/30/2016	ADES-I-008	0.67											
Boys Rest Room near Library (Far Left)	Sink	6/30/2016	ADES-I-009	1.11											
Boys Rest Room near Library (Middle Left)	Sink	6/30/2016	ADES-I-010	1.38											
Boys Rest Room near Library (Center)	Sink	6/30/2016	ADES-I-011	0.88											
Boys Rest Room near Library (Mid Right)	Sink	6/30/2016	ADES-I-012	1.06											
Boys Rest Room near Library (Far Right)	Sink	6/30/2016	ADES-I-013	1.19											
Girls Rest Room near Library (Far Left)	Sink	6/30/2016	ADES-I-014	1.04											
Girls Rest Room near Library (Mid Left)	Sink	6/30/2016	ADES-I-015	1.07											
Girls Rest Room near Library (Center)	Sink	6/30/2016	ADES-I-016	1.19											
Girls Rest Room near Library (Mid Right)	Sink	6/30/2016	ADES-I-017	1.03											
Girls Rest Room near Library (Far Right)	Sink	6/30/2016	ADES-I-018	1.14											
Room 8	Fountain	6/30/2016	ADES-I-019	1.30											
Room 8	Sink	6/30/2016	ADES-I-020	3.52											
Library by Computer Lab	Sink	6/30/2016	ADES-I-021	13.80											
Library work room	Sink	6/30/2016	ADES-I-022	13.60											
Room 9	Fountain	6/30/2016	ADES-I-023	3.61											
Room 9	Sink	6/30/2016	ADES-I-024	3.32											
Room 10	Fountain	6/30/2016	ADES-I-025	0.86											
Room 10	Sink	6/30/2016	ADES-I-026	8.47											
Room 11	Fountain	6/30/2016	ADES-I-027	2.17											
Room 11	Sink	6/30/2016	ADES-I-028	8.46											
Room 12	Fountain	6/30/2016	ADES-I-029	0.88											
Room 12	Sink	6/30/2016	ADES-I-030	10.60											
Room 12b	Sink	6/30/2016	ADES-I-031	4.63											
Boys Rest Room by Room 13 (Left)	Sink	6/30/2016	ADES-I-032	2.90											
Boys Rest Room by Room 13 (Right)	Sink	6/30/2016	ADES-I-033	2.37											
Outside Boys Rest Room by Room 13	Fountain	6/30/2016	ADES-I-034	0.76											
Girls Rest Room by Room 13 (Left)	Sink	6/30/2016	ADES-I-035	2.26											
Girls Rest Room by Room 13 (Right)	Sink	6/30/2016	ADES-I-036	1.80											
Room 13	Fountain	6/30/2016	ADES-I-037	1.86											
Room 13	Sink	6/30/2016	ADES-I-038	0.99											
Room 14	Fountain	6/30/2016	ADES-I-039	1.48											
Room 14	Sink	6/30/2016	ADES-I-040	232.00	8/29/2016	ADES-I-075	7.29	9/2/2016	9/7/2016	ADES-I-077	186.00	Replaced nipples and stops(gate valves)	10/12/2016	ADES-I-078	5.48
Room 15 - Missed on the original draw	Fountain	9/6/2016	ADES-I-041	See #076											
Room 15	Sink	6/30/2016	ADES-I-042	1.98											
Room 16	Fountain	6/30/2016	ADES-I-043	4.64											
Room 16	Sink	6/30/2016	ADES-I-044	3.32											
Room 18	Fountain	6/30/2016	ADES-I-045	3.64											
Room 18	Sink	6/30/2016	ADES-I-046	12.80											
Lower Level Staff area Kitchen	Sink	6/30/2016	ADES-I-047	1.74											
Lower Level Staff area Kitchen	Insta-Hot	6/30/2016	ADES-I-048	ND											
Lower Level Staff Area Kitchen Rest Room (South Side)	Sink	6/30/2016	ADES-I-049	0.95											
Lower Level Staff Area Kitchen Rest Room (North Side)	Sink	6/30/2016	ADES-I-050	1.80											
Room by Learning Center (Learning Center Office)	Fountain	6/30/2016	ADES-I-051	10.70											
Room by Learning Center (Learning Center Office)	Sink	6/30/2016	ADES-I-052	0.93											
Room 1 (2B)	Fountain	6/30/2016	ADES-I-053	6.07											
Room 1 (2B)	Sink	6/30/2016	ADES-I-054	2.42											
Girls Rest Room by Room 2	Sink	6/30/2016	ADES-I-055	0.68											
Room 2	Fountain	6/30/2016	ADES-I-056	2.99											
Room 2	Sink	6/30/2016	ADES-I-057	1.91											
Room 3	Fountain	6/30/2016	ADES-I-058	3.46											

Using EPA's water sampling method for schools, action level is >20 parts per billion (ppb). Samples that tested above the action level are highlighted.

Eugene School District 4J  
 Water Quality: Lead Testing Results

Eugene School District 4J - Location	Fixture Type	First Draw			Flushed Draw			New Fixture First Draw				Follow Up - New Fixture Draw			
		Date Sampled	Sample ID #	Result (ppb)	Date Sampled	Sample ID #	Result (ppb)	Fixture Replaced	Date Sampled	Sample ID #	Result (ppb)	Additional Action	Date Sampled	Sample ID #	Result (ppb)
<b>Adams Elementary School</b>															
Room 3	Sink	6/30/2016	ADES-I-059	8.58											
Room 4	Sink	6/30/2016	ADES-I-060	0.70											
Room 4	Fountain	6/30/2016	ADES-I-061	2.17											
Room 5	Fountain	6/30/2016	ADES-I-062	0.69											
Room 5	Sink	6/30/2016	ADES-I-063	7.30											
Room 6	Fountain	6/30/2016	ADES-I-064	1.57											
Room 6	Sink	6/30/2016	ADES-I-065	2.26											
Room 7	Fountain	6/30/2016	ADES-I-066	3.18											
Room 7	Sink	6/30/2016	ADES-I-067	1.19											
Boys Rest Room by Room 7 (Left)	Sink	6/30/2016	ADES-I-068	7.26											
Boys Rest Room by Room 7 (Right)	Sink	6/30/2016	ADES-I-069	7.27											
Girls Rest Room by Room 7 (Left)	Sink	6/30/2016	ADES-I-070	10.90											
Girls Rest Room by Room 7 (Right)	Sink	6/30/2016	ADES-I-071	6.52											
Wheelchair Access Rest Rooms by Room 3&4	Sink	6/30/2016	ADES-I-072	0.31											
Room 17	Fountain	8/3/2016	ADES-I-073	1.77											
Room 17	Sink	8/3/2016	ADES-I-074	6.50											
Room 15 - Missed - Labeled as ADES-I-041 above	Fountain	9/6/2016	ADES-I-076	3.04											
Health Room Refrigerator - In Freezer	Ice Machine	10/13/2016	ADES-I-079	1.01											

Using EPA's water sampling method for schools, action level is >20 parts per billion (ppb). Samples that tested above the action level are highlighted.