

Eugene School District 4J
Water Quality: Lead Testing Results

Eugene School District 4J - Location	Fixture Type	First Draw			Flushed Draw			New Fixture First Draw			
		Date Sampled	Sample ID #	Result (ppb)	Date Sampled	Sample ID #	Result (ppb)	Fixture Replaced	Date Sampled	Sample ID #	Result (ppb)
Edison Elementary School											
Nurses Office	Fountain	7/27/2016	EDES-I-001	2.76							
Nurses Office	Sink	7/27/2016	EDES-I-002	2.43							
Room 16	Fountain	7/27/2016	EDES-I-003	2.17							
Room 16	Sink	7/27/2016	EDES-I-004	3.52							
Hallway between Room 16 & 17	Fountain	7/27/2016	EDES-I-005	2.88							
Room 17	Fountain	7/27/2016	EDES-I-006	2.61							
Room 17	Sink	7/27/2016	EDES-I-007	4.49							
Staff Room	Sink	7/27/2016	EDES-I-008	1.47							
Staff Room	Instaa-Hot	7/27/2016	EDES-I-009	4.60							
Girls Restroom by Room 18 (left)	Sink	7/27/2016	EDES-I-010	3.63							
Girls Restroom by Room 18 (mid)	Sink	7/27/2016	EDES-I-011	3.08							
Girls Restroom by Room 18 (Right)	Sink	7/27/2016	EDES-I-012	1.96							
Room 18	Fountain	7/27/2016	EDES-I-013	2.96							
Room 18	Sink	7/27/2016	EDES-I-014	2.58							
Room 19	Fountain	7/27/2016	EDES-I-015	5.20							
Room 19	Sink	7/27/2016	EDES-I-016	10.90							
Hallway outside of Office	Fountain	7/27/2016	EDES-I-017	2.91							
Boys Restroom next to Room 13 (left)	Sink	7/27/2016	EDES-I-018	3.31							
Boys Restroom next to Room 13 (right)	Sink	7/27/2016	EDES-I-019	4.73							
Room 13	Fountain	7/27/2016	EDES-I-020	5.01							
Room 13	Sink	7/27/2016	EDES-I-021	11.50							
Room 14	Fountain	7/27/2016	EDES-I-022	5.98							
Room 14	Sink	7/27/2016	EDES-I-023	15.00							
Gym (left)	Fountain	7/27/2016	EDES-I-024	4.62							
Gym (Right)	Fountain	7/27/2016	EDES-I-025	2.16							
Room 13	Fountain	7/27/2016	EDES-I-026	4.76							
Room 13	Sink	7/27/2016	EDES-I-027	6.91							
Room 11	Fountain	7/27/2016	EDES-I-028	3.74							
Room 11	Sink	7/27/2016	EDES-I-029	5.55							
Hallway across from Room 11	Fountain	7/27/2016	EDES-I-030	5.96							
Boys Restroom across from Room 11 (left)	Sink	7/27/2016	EDES-I-031	7.65							
Boys Restroom across from Room 11 (right)	Sink	7/27/2016	EDES-I-032	5.07							
Girls Restroom next to Room 9 (left)	Sink	7/27/2016	EDES-I-033	7.23							
Girls Restroom next to Room 9 (right)	Sink	7/27/2016	EDES-I-034	6.24							
Room 9	Fountain	7/27/2016	EDES-I-035	6.57							
Room 9	Sink	7/27/2016	EDES-I-036	5.25							
Room 10	Sink	7/27/2016	EDES-I-037	7.89							
Room 1	Sink	7/27/2016	EDES-I-038	6.38							
Kitchen East Wall	Sink	7/27/2016	EDES-I-039	4.39							
Kitchen Dishwasher Sprayer	Sink	7/27/2016	EDES-I-040	6.32							
Speech	Sink	7/27/2016	EDES-I-041	9.95							
Wheelchair access Restroom between Speech & Girls Restroom	Sink	7/27/2016	EDES-I-042	2.63							
Girls Restroom (left)	Sink	7/27/2016	EDES-I-043	3.06							

Using EPA's water sampling method for schools, action level is >20 parts per billion (ppb). Samples that tested above the action level are highlighted.

Eugene School District 4J
Water Quality: Lead Testing Results

Eugene School District 4J - Location	Fixture Type	First Draw			Flushed Draw			New Fixture First Draw			
		Date Sampled	Sample ID #	Result (ppb)	Date Sampled	Sample ID #	Result (ppb)	Fixture Replaced	Date Sampled	Sample ID #	Result (ppb)
Edison Elementary School											
Girls Restroom (right)	Sink	7/27/2016	EDES-I-044	4.97							
Boys Restroom (left)	Sink	7/27/2016	EDES-I-045	5.91							
Boys Restroom (right)	Sink	7/27/2016	EDES-I-046	6.48							
Outside Restrooms in downstairs hallway	Fountain	7/27/2016	EDES-I-047	3.55							
Room 2	Sink	7/27/2016	EDES-I-048	5.99							
Room 3	Fountain	7/27/2016	EDES-I-049	9.82							
Room 3	Sink	7/27/2016	EDES-I-050	5.19							
Room 4	Sink	7/27/2016	EDES-I-051	2.82							
Exterior by Boiler Room	Fountain	7/27/2016	EDES-I-052	6.20							
Staff Restroom, Lower Gym, East Wall	Sink	7/28/2016	EDES-I-053	33.30	10/1/2016	EDES-F-054	ND	10/7/2016	10/13/2016	EDES-I-055	2.32
Staff Room Refrigerator Ice Maker - In Freezer - Not Operational	Ice Maker										

Using EPA's water sampling method for schools, action level is >20 parts per billion (ppb). Samples that tested above the action level are highlighted.