

Eugene School District 4J  
Water Quality: Lead Testing Results

Eugene School District 4J - Location	Fixture Type	First Draw			Flushed Draw			New Fixture First Draw			
		Date Sampled	Sample ID #	Result (ppb)	Date Sampled	Sample ID #	Result (ppb)	Fixture Replaced	Date Sampled	Sample ID #	Result (ppb)
<b>Fountain Villa Apartments</b>											
Apt 2 Kitchen	Sink	8/5/2016	FVA-I-001	0.86							
Apt 2 Restroom	Sink	8/5/2016	FVA-I-002	6.30							
Apt 44 Kitchen	Sink	8/5/2016	FVA-I-003	3.70							
Apt 44 Downstairs Restroom	Sink	8/5/2016	FVA-I-004	<b>91.60</b>	10/1/2016	FVA-F-007	ND	10/21/2016	11/1/2016	FVA-I-009	ND
Apt 44 Upstairs Restroom	Sink	8/5/2016	FVA-I-005	<b>29.70</b>	10/1/2016	FVA-F-008	ND	10/21/2016	11/1/2016	FVA-I-010	17.40
Apt 44 Upstairs Bedroom	Sink	8/5/2016	FVA-I-006	4.31							

Using EPA's water sampling method for schools, action level is >20 parts per billion (ppb). Samples that tested above the action level are highlighted.