

Eugene School District 4J
Water Quality: Lead Testing Results

Eugene School District 4J - Location	Fixture Type	First Draw			Flushed Draw			New Fixture First Draw			
		Date Sampled	Sample ID #	Result (ppb)	Date Sampled	Sample ID #	Result (ppb)	Fixture Replaced	Date Sampled	Sample ID #	Result (ppb)
Transportation Department											
Staff Building Kitchen	Sink	6/30/2016	ETRN-I-001	0.39							
Staff Building Kitchen	Sink	6/30/2016	ETRN-I-002	0.73							
Staff Building Restroom	Sink	6/30/2016	ETRN-I-003	1.36							
Transportation Building Copy Area	Insta-Hot	6/30/2016	ETRN-I-004	0.74							
Transportation Building Copy Area	Sink	6/30/2016	ETRN-I-005	2.06							
Transportation Building Break Room	Sink	6/30/2016	ETRN-I-006	ND							
Transportation Building Break Room	Sink	6/30/2016	ETRN-I-007	0.93							
Transportation Building Women's Restroom (West Sink)	Sink	6/30/2016	ETRN-I-008	1.08							
Transportation Building Women's Restroom (East Sink)	Sink	6/30/2016	ETRN-I-009	0.58							
Transportation Building Men's Restroom (West Sink)	Sink	6/30/2016	ETRN-I-010	0.37							
Transportation Building Men's Restroom (East Sink)	Sink	6/30/2016	ETRN-I-011	1.61							
Garage Building Office Restroom	Sink	6/30/2016	ETRN-I-012	ND							
Garage Building Break Room	Sink	6/30/2016	ETRN-I-013	0.26							
Locker Room Restroom	Sink	7/21/2016	ETRN-I-014	ND							

Using EPA's water sampling method for schools, action level is >20 parts per billion (ppb). Samples that tested above the action level are highlighted.