





Eugene School District 4J  
Water Quality: Lead Testing Results

Eugene School District 4J - Location	Fixture Use	Fixture Type	First Draw			Flushed Draw			New Fixture First Draw				Follow Up - New Fixture Draw					
			Date Sampled	Sample ID #	Result (ppb)	Date Sampled	Sample ID #	Result (ppb)	Fixture Replaced	Date Sampled	Sample ID #	Result (ppb)	Additional Action	Date Flushed	Date Sampled	Date Received	Sample ID #	Result (ppb)
<b>North Eugene High School</b>																		
Student Store, Adjacent to Kitchen, North	Food Preparation	Sink	9/2/16	NEHS-I-209	5.05													
Student Store, Adjacent to Kitchen, South	Food Preparation	Sink	9/2/16	NEHS-I-210	10.50													
Girls Locker Room, Staff Office Restroom	Other Human Consumption	Sink	9/2/16	NEHS-I-211	9.15													
Room 305 Women's Restroom	Other Human Consumption	Sink	9/2/16	NEHS-I-212	9.42													
Room 305 Men's Restroom	Other Human Consumption	Sink	9/2/16	NEHS-I-213	4.95													
Room 304 Storage Room	Other Human Consumption	Sink	9/2/16	NEHS-I-214	12.90													
Woodshop	Drinking Fountain	Fountain	9/2/16	NEHS-I-215	ND													
Woodshop Fixture Between Hand and Eyewash Sinks	Other Human Consumption	Sink	9/2/16	NEHS-I-216	ND													
Hallway Near Room 206	Drinking Fountain	Fountain	9/2/16	NEHS-I-217	19.90													
Room 206 Northwest Corner Sink	Other Human Consumption	Sink	9/2/16	NEHS-I-218	4850.00	9/14/16	NEHS-I-227	2.30	10/27/16	11/3/16	NEHS-I-272	21.50	New stops, piping, & supply lines	7/1/17	7/2/17	7/10/17	NEHS-I-307	19.90
Outside Room 502	Drinking Fountain	Fountain	9/2/16	NEHS-I-219	5.66													
Team Room Restroom	Other Human Consumption	Sink	9/2/16	NEHS-I-220	11.80													
Room 506 East - New Fixtures due to added cabinets Summer 2016	Other Human Consumption	Sink	9/9/16	NEHS-I-221	1.45													
Room 506 West - New Fixtures due to added cabinets Summer 2016	Other Human Consumption	Sink	9/9/16	NEHS-I-222	1.13													
Staff Room Refrigerator - In Door	Drinking Fountain	Dispenser	10/8/16	NEHS-I-235	ND													
Staff Room Refrigerator - In Door	Drinking Fountain	Ice Machine	10/8/16	NEHS-I-236	ND													
Room 305 - New Daycare space	Other Human Consumption	Sink	12/1/16	NEHS-I-283	2.58													
Swede Johnson Stadium - Front of Concessions Stand	Drinking Fountain	Fountain	7/6/16	SJSTA-I-001	0.76													
Swede Johnson Stadium - North Side Behind Bleachers Women's Restroom Left	Other Human Consumption	Sink	7/6/16	SJSTA-I-002	1.31													
Swede Johnson Stadium - North Side Behind Bleachers Women's Restroom Right	Other Human Consumption	Sink	7/6/16	SJSTA-I-003	0.47													
Swede Johnson Stadium - North Side Behind Bleachers Men's Restroom	Other Human Consumption	Sink	7/6/16	SJSTA-I-004	0.47													
Swede Johnson Stadium - 3rd Baseline Dugout	Drinking Fountain	Fountain	7/6/16	SJSTA-I-005	0.23													
Swede Johnson Stadium - 1st Baseline Dugout	Drinking Fountain	Fountain	7/6/16	SJSTA-I-006	0.56													
Swede Johnson Stadium - Yard Hydrant at West Side of Track	Drinking Fountain	Hose Bib	7/6/16	SJSTA-I-007	2.19													
Swede Johnson Stadium - Concessions Food Prep North Wall	Food Preparation	Sink	7/6/16	SJSTA-I-008	0.77													
Swede Johnson Stadium - Concessions Handwash on Center Island	Food Preparation	Sink	7/6/16	SJSTA-I-009	0.86													
Swede Johnson Stadium - Track Concessions Large Basin	Food Preparation	Sink	7/6/16	SJSTA-I-010	2.48													