

Eugene School District 4J
Water Quality: Lead Testing Results

| Eugene School District 4J - Location | Fixture Type | First Draw | | | Flushed Draw | | | New Fixture First Draw | | | | Follow Up - New Fixture Draw | | | | |
|---|--------------|--------------|-------------|--------------|--------------|-------------|--------------|------------------------|--------------|-------------|--------------|---|--------------|--------------|-------------|--------------|
| | | Date Sampled | Sample ID # | Result (ppb) | Date Sampled | Sample ID # | Result (ppb) | Fixture Replaced | Date Sampled | Sample ID # | Result (ppb) | Additional Action | Date Flushed | Date Sampled | Sample ID # | Result (ppb) |
| Room 20 | Sink | 6/21/16 | KELMS-I-001 | 1.74 | | | | | | | | | | | | |
| Room 21 | Sink | 6/21/16 | KELMS-I-002 | 2.83 | | | | | | | | | | | | |
| Room 22 | Sink | 6/21/16 | KELMS-I-003 | 18.40 | | | | | | | | | | | | |
| Room 23 | Sink | 6/21/16 | KELMS-I-004 | 3.71 | | | | | | | | | | | | |
| Room 25 | Sink | 6/21/16 | KELMS-I-005 | 24.10 | 7/19/16 | KELMS-F-099 | 3.19 | 8/10/16 | 8/12/16 | KELMS-I-119 | 1.16 | | | | | |
| Room 26 | Sink | 6/21/16 | KELMS-I-006 | 15.70 | | | | | | | | | | | | |
| Room 27 | Sink | 6/21/16 | KELMS-I-007 | 9.20 | | | | | | | | | | | | |
| Room 28 | Sink | 6/21/16 | KELMS-I-008 | 2.86 | | | | | | | | | | | | |
| Room 29 | Sink | 6/21/16 | KELMS-I-009 | 6.84 | | | | | | | | | | | | |
| Room 30 | Sink | 6/21/16 | KELMS-I-010 | 16.40 | | | | | | | | | | | | |
| Room 31 (L) | Sink | 6/21/16 | KELMS-I-011 | 3.40 | | | | | | | | | | | | |
| Room 31 (R) | Sink | 6/21/16 | KELMS-I-012 | 5.14 | | | | | | | | | | | | |
| Storage Room in Room 31 | Sink | 6/21/16 | KELMS-I-013 | 42.20 | 7/19/16 | KELMS-F-098 | 7.98 | 8/10/16 | 8/12/16 | KELMS-I-120 | 10.90 | | | | | |
| Boys Restroom by Room 31 Far (L) | Sink | 6/21/16 | KELMS-I-014 | 2.86 | | | | | | | | | | | | |
| Boys Restroom by Room 31 Middle (L) | Sink | 6/21/16 | KELMS-I-015 | 1.36 | | | | | | | | | | | | |
| Boys Restroom by Room 31 Middle (R) | Sink | 6/21/16 | KELMS-I-016 | 0.28 | | | | | | | | | | | | |
| Boys Restroom by Room 31 Far (R) | Sink | 6/21/16 | KELMS-I-017 | ND | | | | | | | | | | | | |
| Hallway East of Inner Gym | Fountain | 6/21/16 | KELMS-I-018 | ND | | | | | | | | | | | | |
| Girls Restroom Across from Gym Far (L) | Sink | 6/21/16 | KELMS-I-019 | 4.23 | | | | | | | | | | | | |
| Girls Restroom Across from Gym Middle (L) | Sink | 6/21/16 | KELMS-I-020 | 1.24 | | | | | | | | | | | | |
| Girls Restroom Across from Gym Middle (R) | Sink | 6/21/16 | KELMS-I-021 | 2.14 | | | | | | | | | | | | |
| Girls Restroom Across from Gym Far (R) | Sink | 6/21/16 | KELMS-I-022 | 3.86 | | | | | | | | | | | | |
| Staff Restroom by Room 24 | Sink | 6/21/16 | KELMS-I-023 | 8.87 | | | | | | | | | | | | |
| Boys Locker Room (L) | Sink | 6/21/16 | KELMS-I-024 | 23.30 | 7/19/16 | KELMS-F-100 | 3.16 | 8/10/16 | 8/12/16 | KELMS-I-121 | 3.44 | | | | | |
| Boys Locker Room Middle | Sink | 6/21/16 | KELMS-I-025 | 24.30 | 7/19/16 | KELMS-F-101 | 2.98 | 8/10/16 | 8/12/16 | KELMS-I-122 | 0.77 | | | | | |
| Boys Locker Room (R) | Sink | 6/21/16 | KELMS-I-026 | 10.40 | | | | | | | | | | | | |
| Outside Boys Locker Room | Fountain | 6/21/16 | KELMS-I-027 | ND | | | | | | | | | | | | |
| Girls Locker Room Staff Office Restroom | Sink | 6/21/16 | KELMS-I-028 | 52.30 | 7/19/16 | KELMS-F-104 | 5.60 | 8/10/16 | 8/12/16 | KELMS-I-123 | 3.37 | | | | | |
| Girls Locker Room (L) | Sink | 6/21/16 | KELMS-I-029 | 1.23 | | | | | | | | | | | | |
| Girls Locker Room Middle (L) | Sink | 6/21/16 | KELMS-I-030 | 16.90 | | | | | | | | | | | | |
| Girls Locker Room Middle (R) | Sink | 6/21/16 | KELMS-I-031 | 20.30 | 7/19/16 | KELMS-F-106 | 2.50 | 8/10/16 | 8/12/16 | KELMS-I-124 | 0.80 | | | | | |
| Girls Locker Room (R) | Sink | 6/21/16 | KELMS-I-032 | 6.00 | | | | | | | | | | | | |
| ADA Restroom by Room 19 | Sink | 6/21/16 | KELMS-I-033 | 3.90 | | | | | | | | | | | | |
| Hallway Across from Library | Fountain | 6/21/16 | KELMS-I-034 | ND | | | | | | | | | | | | |
| Boys Restroom Across from Library | Sink | 6/21/16 | KELMS-I-035 | ND | | | | | | | | | | | | |
| Office by Library | Sink | 6/21/16 | KELMS-I-036 | 23.10 | 7/19/16 | KELMS-F-105 | 3.89 | 8/10/16 | 8/12/16 | KELMS-I-125 | 5.49 | | | | | |
| Room 16 (L) | Sink | 6/21/16 | KELMS-I-037 | 18.30 | | | | | | | | | | | | |
| Room 16 Middle | Sink | 6/21/16 | KELMS-I-038 | 6.17 | | | | | | | | | | | | |
| Room 16 (R) | Sink | 6/21/16 | KELMS-I-039 | 31.10 | 7/19/16 | KELMS-F-107 | 2.94 | 8/10/16 | 8/12/16 | KELMS-I-126 | 2.78 | | | | | |
| Girls Restroom Between Rooms 15 & 17 (L) | Sink | 6/21/16 | KELMS-I-040 | 2.69 | | | | | | | | | | | | |
| Girls Restroom Between Rooms 15 & 17 (R) | Sink | 6/21/16 | KELMS-I-041 | 2.93 | | | | | | | | | | | | |
| Room 14 | Sink | 6/21/16 | KELMS-I-042 | 3.58 | | | | | | | | | | | | |
| Room 15 | Sink | 6/21/16 | KELMS-I-043 | 1.54 | | | | | | | | | | | | |
| Room 12 | Sink | 6/21/16 | KELMS-I-044 | 7.06 | | | | | | | | | | | | |
| Girls Restroom Between Rooms 10 & 12 (L) | Sink | 6/21/16 | KELMS-I-045 | 1.46 | | | | | | | | | | | | |
| Girls Restroom Between Rooms 10 & 12 (R) | Sink | 6/21/16 | KELMS-I-046 | 0.38 | | | | | | | | | | | | |
| Hallway Between Rooms 11 & 13 | Fountain | 6/21/16 | KELMS-I-047 | ND | | | | | | | | | | | | |
| Outside Health Office | Sink | 6/21/16 | KELMS-I-048 | 12.90 | | | | | | | | | | | | |
| Restroom in Health Office | Sink | 6/21/16 | KELMS-I-049 | 6.50 | | | | | | | | | | | | |
| Staff Breakroom (L) | Sink | 6/21/16 | KELMS-I-050 | 0.24 | | | | | | | | | | | | |
| Staff Breakroom (R) | Insta-Hot | 6/21/16 | KELMS-I-051 | ND | | | | | | | | | | | | |
| Staff Restroom Women's | Sink | 6/21/16 | KELMS-I-052 | 1.52 | | | | | | | | | | | | |
| Staff Restroom Men's | Sink | 6/21/16 | KELMS-I-053 | 0.49 | | | | | | | | | | | | |
| Outside Staff Room West Hallway | Fountain | 6/21/16 | KELMS-I-054 | 0.38 | | | | | | | | | | | | |
| Room 6 West Wall (L) | Sink | 6/21/16 | KELMS-I-055 | 263.00 | 7/19/16 | KELMS-F-108 | 5.70 | 8/10/16 | 8/12/16 | KELMS-I-127 | 17.00 | | | | | |
| Room 6 West Wall Middle | Sink | 6/21/16 | KELMS-I-056 | 6.13 | | | | | | | | | | | | |
| Room 6 West Wall (R) | Sink | 6/21/16 | KELMS-I-057 | 3.06 | | | | | | | | | | | | |
| Room 6 East Wall (L) | Sink | 6/21/16 | KELMS-I-058 | 5.19 | | | | | | | | | | | | |
| Room 6 East Wall Middle | Sink | 6/21/16 | KELMS-I-059 | 4.60 | | | | | | | | | | | | |
| Room 6 East Wall (R) | Sink | 6/21/16 | KELMS-I-060 | 2.81 | | | | | | | | | | | | |
| Girls Restroom by Room 6 (L) | Sink | 6/21/16 | KELMS-I-061 | 1.08 | | | | | | | | | | | | |
| Girls Restroom by Room 6 (R) | Sink | 6/21/16 | KELMS-I-062 | ND | | | | | | | | | | | | |
| Boys Restroom Across from Cafeteria (L) | Sink | 6/21/16 | KELMS-I-063 | ND | | | | | | | | | | | | |
| Boys Restroom Across from Cafeteria (R) | Sink | 6/21/16 | KELMS-I-064 | 0.26 | | | | | | | | | | | | |
| Kitchen Northeast Corner | Sink | 6/21/16 | KELMS-I-065 | 0.67 | | | | | | | | | | | | |
| Kitchen South Wall (L) - Hand Wash | Sink | 6/21/16 | KELMS-I-066 | 1.39 | | | | | | | | | | | | |
| Kitchen South Wall (R) - Produce | Sink | 6/21/16 | KELMS-I-067 | 10.20 | | | | | | | | | | | | |
| Kitchen Restroom | Sink | 6/21/16 | KELMS-I-068 | 6.33 | | | | | | | | | | | | |
| Hallway Across from Small Gym | Fountain | 6/21/16 | KELMS-I-069 | ND | | | | | | | | | | | | |
| Small Gym Office | Sink | 6/21/16 | KELMS-I-070 | 25.30 | 7/19/16 | KELMS-F-109 | 5.97 | 8/10/16 | 8/12/16 | KELMS-I-129 | 6.00 | | | | | |
| Room 3 North Wall | Sink | 6/21/16 | KELMS-I-071 | 68.30 | 7/19/16 | KELMS-F-110 | 11.40 | 8/10/16 | 8/12/16 | KELMS-I-128 | 7.21 | | | | | |
| Room 3 Just Inside Door | Sink | 6/21/16 | KELMS-I-072 | ND | | | | | | | | | | | | |
| Hallway Between Rooms 2 & 3 | Fountain | 6/21/16 | KELMS-I-073 | ND | | | | | | | | | | | | |
| Office in Room 1 | Sink | 6/21/16 | KELMS-I-074 | 20.00 | | | | | | | | | | | | |
| Room 1 | Sink | 6/21/16 | KELMS-I-075 | 1.00 | | | | | | | | | | | | |
| Room 33 Single Nearest Door | Sink | 6/21/16 | KELMS-I-076 | 61.00 | 7/19/16 | KELMS-F-118 | 1.67 | 8/10/16 | 10/1/16 | KELMS-I-137 | 22.50 | Incorrect fixture replaced - Replaced fixture | 10/31/16 | 11/17/16 | KELMS-I-141 | 11.70 |
| Room 33 Double Middle of Room (L) | Sink | 6/21/16 | KELMS-I-077 | 6.10 | | | | | | | | | | | | |
| Room 33 Double Middle of Room (R) | Sink | 6/21/16 | KELMS-I-078 | 4.71 | | | | | | | | | | | | |
| Room 33 Double Back of Room (L) | Sink | 6/21/16 | KELMS-I-079 | 19.90 | | | | | | | | | | | | |

Using EPA's water sampling method for schools, action level is >20 parts per billion (ppb). Samples that tested above the action level are highlighted.

Eugene School District 4J
Water Quality: Lead Testing Results

| Eugene School District 4J - Location | Fixture Type | First Draw | | | Flushed Draw | | | New Fixture First Draw | | | | Follow Up - New Fixture Draw | | | | |
|--|--------------|--------------|-------------|--------------|----------------|----------------|--------------|------------------------|--------------|-------------|--------------|--|-------------------------------|------------------------------|----------------------------------|----------------------|
| | | Date Sampled | Sample ID # | Result (ppb) | Date Sampled | Sample ID # | Result (ppb) | Fixture Replaced | Date Sampled | Sample ID # | Result (ppb) | Additional Action | Date Flushed | Date Sampled | Sample ID # | Result (ppb) |
| Kelly Middle School | | | | | | | | | | | | | | | | |
| Room 33 Double Back of Room (R) | Sink | 6/21/16 | KELMS-I-080 | 17.30 | | | | | | | | | | | | |
| Hallway Outside Room 35 (R) | Fountain | 6/21/16 | KELMS-I-081 | 11.20 | | | | | | | | | | | | |
| Hallway Outside Room 35 (L) | Fountain | 6/21/16 | KELMS-I-082 | 16.00 | | | | | | | | | | | | |
| Boys Restroom by Room 34 (L) | Sink | 6/21/16 | KELMS-I-083 | 34.50 | 7/19/16 | KELMS-F-116 | 4.50 | 8/10/16 | 8/12/16 | KELMS-I-134 | 2.36 | | | | | |
| Boys Restroom by Room 34 (R) | Sink | 6/21/16 | KELMS-I-084 | 1.53 | | | | | | | | | | | | |
| Room 34 Single Nearest Door | Sink | 6/21/16 | KELMS-I-085 | 22.90 | 7/19/16 | KELMS-F-117 | 31.90 | 8/10/16 | 8/12/16 | KELMS-I-133 | 15.10 | | | | | |
| Room 34 Double Middle of Room (L) | Sink | 6/21/16 | KELMS-I-086 | 2.28 | | | | | | | | | | | | |
| Room 34 Double Middle of Room (R) | Sink | 6/21/16 | KELMS-I-087 | 1.29 | | | | | | | | | | | | |
| Room 34 Double Back of Room (L) | Sink | 6/21/16 | KELMS-I-088 | 5.79 | | | | | | | | | | | | |
| Room 34 Double Back of Room (R) | Sink | 6/21/16 | KELMS-I-089 | 3.86 | | | | | | | | | | | | |
| Office Between Rooms 34 & 32 | Sink | 6/21/16 | KELMS-I-090 | 13.50 | | | | | | | | | | | | |
| Girls Restroom Between Rooms 32 & 34 (L) | Sink | 6/21/16 | KELMS-I-091 | 1.39 | | | | | | | | | | | | |
| Girls Restroom Between Rooms 32 & 34 (R) | Sink | 6/21/16 | KELMS-I-092 | 0.90 | | | | | | | | | | | | |
| Room 32 Single at Front of Room | Sink | 6/21/16 | KELMS-I-093 | 13.30 | | | | 8/10/16 | 8/12/16 | KELMS-I-132 | 10.90 | | | | | |
| Room 32 Single Middle Island | Sink | 6/21/16 | KELMS-I-094 | 3.72 | | | | | | | | | | | | |
| Room 32 Double at Back of Room (L) | Sink | 6/21/16 | KELMS-I-095 | 67.10 | 7/19/16 | KELMS-F-114 | 7.69 | 8/10/16 | 8/12/16 | KELMS-I-130 | 5.57 | | | | | |
| Room 32 Double at Back of Room (R) | Sink | 6/21/16 | KELMS-I-096 | 7.77 | 7/19/16 | KELMS-F-115 | 9.12 | 8/10/16 | 8/12/16 | KELMS-I-131 | 11.00 | | | | | |
| Room 32 Single Inside to (L) of Door | Sink | 6/21/16 | KELMS-I-097 | 21.00 | | | | | | | | | | | | |
| Room 33 North Wall | Sink | 7/19/16 | KELMS-I-113 | 93.40 | No Flush Taken | No Flush Taken | | 9/28/16 | 10/1/16 | KELMS-I-138 | 54.70 | 1. Replaced angle stops and nipples. 2. Rplaced all pipe and fittings to floor. | 1. 10/31/2016 2. 7/12/2017 | 1. 11/1/2016 2. 7/13/2017 | 1. KELMS-I-142 2. KELMS-I-143 | 1. 70.90 2. 19.90 |
| Staff Restroom | Sink | 7/19/16 | KELMS-I-102 | ND | | | | | | | | | | | | |
| Staff Room Refrigerator - In Door | Water | 10/8/16 | KELMS-I-139 | ND | | | | | | | | | | | | |
| Staff Room Refrigerator - In Door | Ice Machine | 10/8/16 | KELMS-I-140 | 1.34 | | | | | | | | | | | | |