

Eugene School District 4J
Water Quality: Lead Testing Results

Eugene School District 4J - Location	Fixture Type	First Draw					Flushed Draw					New Fixture First Draw			
		Date Flushed	Date Sampled	Date Received	Sample ID #	Result (ppb)	Date Flushed	Date Sampled	Date Received	Sample ID #	Result (ppb)	Fixture Replaced	Date Sampled	Sample ID #	Result (ppb)
Arts & Technology Academy (NEW)															
Room 139	Sink	8/6/17	8/7/17	8/18/17	NATA-I-001	13.70									
Room 139	Fountain	8/6/17	8/7/17	8/18/17	NATA-I-002	1.53									
Room 140	Sink	8/6/17	8/7/17	8/18/17	NATA-I-003	9.27									
Room 140	Fountain	8/6/17	8/7/17	8/18/17	NATA-I-004	1.86									
Room 141	Sink	8/6/17	8/7/17	8/18/17	NATA-I-005	10.90									
Room 141	Fountain	8/6/17	8/7/17	8/18/17	NATA-I-006	1.26									
Room 141	Sink	8/6/17	8/7/17	8/18/17	NATA-I-007	3.51									
Room 141	Sink	8/6/17	8/7/17	8/18/17	NATA-I-008	1.73									
Room 141	Sink	8/6/17	8/7/17	8/18/17	NATA-I-009	1.81									
Room 141	Sink	8/6/17	8/7/17	8/18/17	NATA-I-010	1.14									
Room 141	Insta-Hot	8/6/17	8/7/17	8/18/17	NATA-I-011	ND									
Room 141	Ice Machine	8/6/17	8/7/17	8/18/17	NATA-I-012	1.75									
Room 142	Sink	8/6/17	8/7/17	8/18/17	NATA-I-013	12.30									
Room 142	Fountain	8/6/17	8/7/17	8/18/17	NATA-I-014	1.27									
Room 143	Sink	8/6/17	8/7/17	8/18/17	NATA-I-015	6.27									
Room 143	Fountain	8/6/17	8/7/17	8/18/17	NATA-I-016	1.41									
Room 144	Sink	8/6/17	8/7/17	8/18/17	NATA-I-017	1.80									
Room 144	Fountain	8/6/17	8/7/17	8/18/17	NATA-I-018	ND									
Exterior Wall - Room 144 - South Side	Hose Bib	8/6/17	8/7/17	8/18/17	NATA-I-019	18.80									
Restroom 152	Sink	8/6/17	8/7/17	8/18/17	NATA-I-020	ND									
Restroom 153	Sink	8/6/17	8/7/17	8/18/17	NATA-I-021	ND									
Room 157A	Sink	8/6/17	8/7/17	8/18/17	NATA-I-022	6.64									
Boys Restroom 150 - Left	Sink	8/6/17	8/7/17	8/18/17	NATA-I-023	ND									
Boys Restroom 150 - Right	Sink	8/6/17	8/7/17	8/18/17	NATA-I-024	ND									
Boys Restroom 150 - Left	Sink	8/6/17	8/7/17	8/18/17	NATA-I-025	ND									
Boys Restroom 150 - Middle	Sink	8/6/17	8/7/17	8/18/17	NATA-I-026	ND									
Boys Restroom 150 - Right	Sink	8/6/17	8/7/17	8/18/17	NATA-I-027	ND									
Corridor H150 - Left	Sink	8/6/17	8/7/17	8/18/17	NATA-I-028	ND									
Corridor H150 - Right	Sink	8/6/17	8/7/17	8/18/17	NATA-I-029	ND									
Corridor H150 - Elkay	Bottle Filler	8/6/17	8/7/17	8/18/17	NATA-I-030	ND									
Girls Restroom 151 - Left	Sink	8/6/17	8/7/17	8/18/17	NATA-I-031	ND									
Girls Restroom 151 - Right	Sink	8/6/17	8/7/17	8/18/17	NATA-I-032	ND									
Girls Restroom 151 - Left	Sink	8/6/17	8/7/17	8/18/17	NATA-I-033	ND									
Girls Restroom 151 - Middle	Sink	8/6/17	8/7/17	8/18/17	NATA-I-034	ND									
Girls Restroom 151 - Right	Sink	8/6/17	8/7/17	8/18/17	NATA-I-035	ND									
Room 131 - Stainless	Sink	8/6/17	8/7/17	8/18/17	NATA-I-036	14.20									
Room 131	Sink	8/6/17	8/7/17	8/18/17	NATA-I-037	7.07									
Room 131	Fountain	8/6/17	8/7/17	8/18/17	NATA-I-038	1.94									
Room 130	Sink	8/6/17	8/7/17	8/18/17	NATA-I-039	8.55									
Room 130	Fountain	8/6/17	8/7/17	8/18/17	NATA-I-040	1.10									
Kitchenette Room 121A	Sink	8/6/17	8/7/17	8/18/17	NATA-I-041	6.96									
Kitchenette Room 121A	Fountain	8/6/17	8/7/17	8/18/17	NATA-I-042	1.16									
Room 132	Sink	8/6/17	8/7/17	8/18/17	NATA-I-043	12.10									
Room 132	Fountain	8/6/17	8/7/17	8/18/17	NATA-I-044	1.30									
Room 135	Sink	8/6/17	8/7/17	8/18/17	NATA-I-045	8.77									
Room 135	Fountain	8/6/17	8/7/17	8/18/17	NATA-I-046	ND									
Room 136	Sink	8/6/17	8/7/17	8/18/17	NATA-I-047	6.47									
Room 136	Fountain	8/6/17	8/7/17	8/18/17	NATA-I-048	1.15									
Room 137	Ice Machine	8/6/17	8/7/17	8/18/17	NATA-I-049	3.70									
Room 137	Sink	8/6/17	8/7/17	8/18/17	NATA-I-050	6.39									
Restroom 137	Sink	8/6/17	8/7/17	8/18/17	NATA-I-051	ND									
Room 138	Sink	8/6/17	8/7/17	8/18/17	NATA-I-052	10.30									
Room 138	Fountain	8/6/17	8/7/17	8/18/17	NATA-I-053	1.76									
Girls Restroom 123 - Left	Sink	8/6/17	8/7/17	8/18/17	NATA-I-054	1.28									
Girls Restroom 123 - Right	Sink	8/6/17	8/7/17	8/18/17	NATA-I-055	1.09									
Girls Restroom 123 - Left	Sink	8/6/17	8/7/17	8/18/17	NATA-I-056	1.25									
Girls Restroom 123 - Middle	Sink	8/6/17	8/7/17	8/18/17	NATA-I-057	2.02									
Girls Restroom 123 - Right	Sink	8/6/17	8/7/17	8/18/17	NATA-I-058	1.40									
Corridor H121 - Left	Fountain	8/6/17	8/7/17	8/18/17	NATA-I-059	ND									
Corridor H121 - Right	Fountain	8/6/17	8/7/17	8/18/17	NATA-I-060	ND									
Boys Restroom 124 - Left	Sink	8/6/17	8/7/17	8/18/17	NATA-I-061	1.40									
Boys Restroom 124 - Right	Sink	8/6/17	8/7/17	8/18/17	NATA-I-062	1.11									
Boys Restroom 124 - Left	Sink	8/6/17	8/7/17	8/18/17	NATA-I-063	ND									
Boys Restroom 124 - Middle	Sink	8/6/17	8/7/17	8/18/17	NATA-I-064	ND									
Boys Restroom 124 - Right	Sink	8/6/17	8/7/17	8/18/17	NATA-I-065	ND									
Band Room	Sink	8/6/17	8/7/17	8/18/17	NATA-I-066	5.12									
Band Room	Fountain	8/6/17	8/7/17	8/18/17	NATA-I-067	2.00									
WCA Restroom - across from band room	Sink	8/6/17	8/7/17	8/18/17	NATA-I-068	ND									
Health Office 104	Sink	8/6/17	8/7/17	8/18/17	NATA-I-069	6.21									
Health Office 104	Fountain	8/6/17	8/7/17	8/18/17	NATA-I-070	6.15									
Health Office 104A - Restroom	Sink	8/6/17	8/7/17	8/18/17	NATA-I-071	ND									
Health Office Freezer	Ice Machine	8/6/17	8/7/17	8/18/17	NATA-I-072	1.19									
Office Restroom - Left	Sink	8/6/17	8/7/17	8/18/17	NATA-I-073	ND									
Office Restroom - Right	Sink	8/6/17	8/7/17	8/18/17	NATA-I-074	ND									

Eugene School District 4J
Water Quality: Lead Testing Results

Eugene School District 4J - Location	Fixture Type	First Draw					Flushed Draw					New Fixture First Draw				
		Date Flushed	Date Sampled	Date Received	Sample ID #	Result (ppb)	Date Flushed	Date Sampled	Date Received	Sample ID #	Result (ppb)	Fixture Replaced	Date Sampled	Sample ID #	Result (ppb)	
Arts & Technology Academy (NEW)																
Meeting Room 110	Sink	8/6/17	8/7/17	8/18/17	NATA-I-075	5.51										
Meeting Room 110	Fountain	8/6/17	8/7/17	8/18/17	NATA-I-076	1.26										
Room 201 - Freezer	Ice Machine	8/6/17	8/7/17	8/18/17	NATA-I-077	2.55										
Room 201	Sink	8/6/17	8/7/17	8/18/17	NATA-I-078	10.10										
Room 201	Sink	8/6/17	8/7/17	8/18/17	NATA-I-079	10.10										
Room 201	Sink	8/6/17	8/7/17	8/18/17	NATA-I-080	6.69										
Room 201	Fountain	8/6/17	8/7/17	8/18/17	NATA-I-081	1.64										
Room 202	Sink	8/6/17	8/7/17	8/18/17	NATA-I-082	8.73										
Room 202	Fountain	8/6/17	8/7/17	8/18/17	NATA-I-083	1.37										
Room 204	Sink	8/6/17	8/7/17	8/18/17	NATA-I-084	11.80										
Room 204	Fountain	8/6/17	8/7/17	8/18/17	NATA-I-085	ND										
Room 205	Sink	8/6/17	8/7/17	8/18/17	NATA-I-086	9.34										
Room 205	Fountain	8/6/17	8/7/17	8/18/17	NATA-I-087	ND										
Room 206A Prep Room	Sink	8/6/17	8/7/17	8/18/17	NATA-I-088	2.43										
Room 206A Prep Room	Insta-Hot	8/6/17	8/7/17	8/18/17	NATA-I-089	ND										
Room 206A Prep Room - Freezer	Ice Machine	8/6/17	8/7/17	8/18/17	NATA-I-090	3.68										
Room 206 - North Wall Right	Sink	8/6/17	8/7/17	8/18/17	NATA-I-091	9.98										
Room 206 - North Wall Left	Sink	8/6/17	8/7/17	8/18/17	NATA-I-092	ND										
Room 206 - West Wall Right	Sink	8/6/17	8/7/17	8/18/17	NATA-I-093	1.36										
Room 206 - West Wall Left	Sink	8/6/17	8/7/17	8/18/17	NATA-I-094	7.90										
Room 206 - West Wall	Fountain	8/6/17	8/7/17	8/18/17	NATA-I-095	3.86										
Room 207	Sink	8/6/17	8/7/17	8/18/17	NATA-I-096	12.20										
Room 207	Fountain	8/6/17	8/7/17	8/18/17	NATA-I-097	1.23										
Room 209	Sink	8/6/17	8/7/17	8/18/17	NATA-I-098	5.68										
Room 209	Fountain	8/6/17	8/7/17	8/18/17	NATA-I-099	ND										
Room 210 - West Wall Right	Sink	8/6/17	8/7/17	8/18/17	NATA-I-100	6.64										
Room 210 - West Wall	Fountain	8/6/17	8/7/17	8/18/17	NATA-I-101	ND										
Room 210 - West Wall Left	Sink	8/6/17	8/7/17	8/18/17	NATA-I-102	4.63										
Room 210 - South Wall Right	Sink	8/6/17	8/7/17	8/18/17	NATA-I-103	1.39										
Room 210 - South Wall Left	Sink	8/6/17	8/7/17	8/18/17	NATA-I-104	1.24										
Room 210A Prep Room	Sink	8/6/17	8/7/17	8/18/17	NATA-I-105	2.51										
Room 210A Prep Room	Insta-Hot	8/6/17	8/7/17	8/18/17	NATA-I-106	ND										
Room 210A Prep Room - Freezer	Ice Machine	8/6/17	8/7/17	8/18/17	NATA-I-107	11.50										
Room 211	Sink	8/6/17	8/7/17	8/18/17	NATA-I-108	11.60										
Room 211	Fountain	8/6/17	8/7/17	8/18/17	NATA-I-109	ND										
Room 212	Sink	8/6/17	8/7/17	8/18/17	NATA-I-110	7.58										
Room 212	Fountain	8/6/17	8/7/17	8/18/17	NATA-I-111	1.31										
Room 213	Sink	8/6/17	8/7/17	8/18/17	NATA-I-112	17.60										
Room 213	Fountain	8/6/17	8/7/17	8/18/17	NATA-I-113	ND										
Corridor H220 - Left Upper	Fountain	8/6/17	8/7/17	8/18/17	NATA-I-114	ND										
Corridor H220 - Right Lower	Fountain	8/6/17	8/7/17	8/18/17	NATA-I-115	ND										
Custodial Closet, Basin Sink	Sink	8/7/17	8/8/17	8/18/17	NATA-I-116	1.24										
Kitchen - Restroom	Sink	8/7/17	8/8/17	8/18/17	NATA-I-117	ND										
Kitchen - West Island - North	Sink	8/7/17	8/8/17	8/18/17	NATA-I-118	1.12										
Kitchen - West Island - South	Sink	8/7/17	8/8/17	8/18/17	NATA-I-119	8.47										
Kitchen - Middle West Island - South	Sink	8/7/17	8/8/17	8/18/17	NATA-I-120	5.01										
Kitchen - Middle West Island - North	Sprayer	8/7/17	8/8/17	8/18/17	NATA-I-121	8.54										
Kitchen - Middle East - South Hand Wash	Sink	8/7/17	8/8/17	8/18/17	NATA-I-122	1.38										
Kitchen - Middle East - North Hand Wash	Sink	8/7/17	8/8/17	8/18/17	NATA-I-123	1.88										
Kitchen - Dish Pit	Sink	8/7/17	8/8/17	8/18/17	NATA-I-124	1.11										
Kitchen - Dish Pit	Sprayer	8/7/17	8/8/17	8/18/17	NATA-I-125	ND										
Kitchen - East Wall - North	Sink	8/7/17	8/8/17	8/18/17	NATA-I-126	6.45										
Kitchen - East Wall - South	Sink	8/7/17	8/8/17	8/18/17	NATA-I-127	6.24										
Staff Room 228 - East Wall	Sink	8/7/17	8/8/17	8/18/17	NATA-I-128	4.96										
Boys Restroom 220 - East Wall - North	Sink	8/7/17	8/8/17	8/18/17	NATA-I-129	ND										
Boys Restroom 220 - East Wall - South	Sink	8/7/17	8/8/17	8/18/17	NATA-I-130	ND										
Boys Restroom 220 - West Wall - South	Sink	8/7/17	8/8/17	8/18/17	NATA-I-131	ND										
Boys Restroom 220 - West Wall - Middle	Sink	8/7/17	8/8/17	8/18/17	NATA-I-132	ND										
Boys Restroom 220 - West Wall - North	Sink	8/7/17	8/8/17	8/18/17	NATA-I-133	1.32										
Girls Restroom 221 - East Wall - North	Sink	8/7/17	8/8/17	8/18/17	NATA-I-134	1.76										
Girls Restroom 221 - East Wall - South	Sink	8/7/17	8/8/17	8/18/17	NATA-I-135	1.19										
Girls Restroom 221 - West Wall - South	Sink	8/7/17	8/8/17	8/18/17	NATA-I-136	1.84										
Girls Restroom 221 - West Wall - Middle	Sink	8/7/17	8/8/17	8/18/17	NATA-I-137	1.40										
Girls Restroom 221 - West Wall - North	Sink	8/7/17	8/8/17	8/18/17	NATA-I-138	1.47										
Corridor H121	Bottle Filler	8/23/17	8/24/17	9/7/17	NATA-I-139	ND										
Kitchen - Middle West Island - South Hand Wash	Sink	8/23/17	8/24/17	9/7/17	NATA-I-140	1.41										
Kitchen - Steam Kettle	Sink	8/23/17	8/24/17	9/7/17	NATA-I-141	1.73										
Corridor H220	Bottle Filler	8/23/17	8/24/17	9/7/17	NATA-I-142	ND										
Staff Room 228 - West Refer Unit	Dispenser	8/23/17	8/24/17	9/7/17	NATA-I-143	ND										
Staff Room 228 - West Refer Unit	Ice Machine	8/23/17	8/24/17	9/7/17	NATA-I-144	ND										
Staff Room 228 - East Refer Unit	Dispenser	8/23/17	8/24/17	9/7/17	NATA-I-145	ND										
Staff Room 228 - East Refer Unit	Ice Machine	8/23/17	8/24/17	9/7/17	NATA-I-146	ND										
Restroom 222	Sink	8/23/17	8/24/17	9/7/17	NATA-I-147	2.32										
Restroom 223	Sink	8/23/17	8/24/17	9/7/17	NATA-I-148	2.14										

Eugene School District 4J
Water Quality: Lead Testing Results

Eugene School District 4J - Location	Fixture Type	First Draw					Flushed Draw					New Fixture First Draw				
		Date Flushed	Date Sampled	Date Received	Sample ID #	Result (ppb)	Date Flushed	Date Sampled	Date Received	Sample ID #	Result (ppb)	Fixture Replaced	Date Sampled	Sample ID #	Result (ppb)	
Arts & Technology Academy (NEW)																
Boys Locker Room 174 - East	Sink	8/23/17	8/24/17	9/7/17	NATA-I-149	1.41										
Boys Locker Room 174 - Middle	Sink	8/23/17	8/24/17	9/7/17	NATA-I-150	1.03										
Boys Locker Room 174 - West	Sink	8/23/17	8/24/17	9/7/17	NATA-I-151	1.10										
Corridor H171 - East	Fountain	8/23/17	8/24/17	9/7/17	NATA-I-152	1.06										
Corridor H171 - West	Fountain	8/23/17	8/24/17	9/7/17	NATA-I-153	ND										
Corridor H171	Bottle Filler	8/23/17	8/24/17	9/7/17	NATA-I-154	ND										
Girls Locker Room 173 - South Wall - East	Sink	8/23/17	8/24/17	9/7/17	NATA-I-155	1.43										
Girls Locker Room 173 - South Wall - Middle	Sink	8/23/17	8/24/17	9/7/17	NATA-I-156	1.10										
Girls Locker Room 173 - South Wall - West	Sink	8/23/17	8/24/17	9/7/17	NATA-I-157	ND										
Girls Locker Room 173 - North Wall - West	Sink	8/23/17	8/24/17	9/7/17	NATA-I-158	ND										
Girls Locker Room 173 - North Wall - East	Sink	8/23/17	8/24/17	9/7/17	NATA-I-159	ND										
Exterior, Outside Office, Near Main Entrance	Hose Bib	8/23/17	8/24/17	9/7/17	NATA-I-160	7.57										
Exterior, Outside Pump Room 126, Non Potable, Reclaimed water.	Hose Bib	8/23/17	8/24/17	9/7/17	NATA-I-161	22.50	9/5/17	9/6/17	9/19/17	NATA-F-163	2.40	Sample from reclaimed source. Code reqd source signage in place.				
Exterior, Outside Kitchen/Cafeteria	Hose Bib	8/23/17	8/24/17	9/11/17	NATA-I-162	15.00										
Custodial Office Refer	Dispenser	9/26/17	9/27/17	10/3/17	NATA-I-164	ND										
Custodial Office Refer	Ice Machine	9/26/17	9/27/17	10/3/17	NATA-I-165	ND										
Health Office Refer	Dispenser	9/26/17	9/27/17	10/3/17	NATA-I-166	ND										
Health Office Refer	Ice Machine	9/26/17	9/27/17	10/3/17	NATA-I-167	ND										
Kitchen Oven, Upper Alto Shaam, Non-Potable Hose	Hose	9/27/17	9/28/17	10/3/17	NATA-I-168	1.55										
Room 201, Refer, Pitcher Filler	Dispenser	9/27/17	9/28/17	10/3/17	NATA-I-169	3.63										
Room 137, Refer, Pitcher Filler	Dispenser	9/27/17	9/28/17	10/3/17	NATA-I-170	ND										
Fixture Types: DF= Drinking Fountain S= Sink IH= Instahot FR= Fridge HB= Hose Bib																
Total Samples Taken	170.00															
		Total Elevated on 1st Draw					169.00									
							Total Elevated on Flush Draw					1.00				
												Total Elevated on Final/Replacement Draw				0.00