

Eugene School District 4J
Water Quality: Lead Testing Results

Eugene School District 4J - Location	Fixture Type	First Draw			Flushed Draw			New Fixture First Draw				Follow Up - New Fixture Draw			
		Date Sampled	Sample ID #	Result (ppb)	Date Sampled	Sample ID #	Result (ppb)	Fixture Replaced	Date Sampled	Sample ID #	Result (ppb)	Additional Action	Date Sampled	Sample ID #	Result (ppb)
Camas Ridge Community School															
Room 8	Fountain	7/13/2016	CRCES-I-001	4.16											
Room 8	Sink	7/13/2016	CRCES-I-002	3.02											
East wing Boys Restroom (East Fixture)	Sink	7/13/2016	CRCES-I-003	0.98											
East wing Boys Restroom (West Fixture)	Sink	7/13/2016	CRCES-I-004	0.70											
Room 7	Fountain	7/13/2016	CRCES-I-005	0.51											
Room 7	Sink	7/13/2016	CRCES-I-006	9.43											
East Wing Girls Restroom (West Fixture)	Sink	7/13/2016	CRCES-I-007	2.51											
East Wing Girls Restroom (East Fixture)	Sink	7/13/2016	CRCES-I-008	1.30											
Room 5	Sink	7/13/2016	CRCES-I-009	38.80	8/30/2016	CRCES-F-066	3.95	9/6/2016	9/6/2016	CRCES-I-070	295.00	Removed brass hose bib inline w/ sink	2/3/2017	CRCES-I-082	6.78
Room 4	Sink	7/13/2016	CRCES-I-010	10.90											
Room 6	Fountain	7/13/2016	CRCES-I-011	1.13											
Room 6	Sink	7/13/2016	CRCES-I-012	3.49											
Room 3	Fountain	7/13/2016	CRCES-I-013	10.80											
Room 3	Sink	7/13/2016	CRCES-I-014	30.90	8/30/2016	CRCES-F-065	3.66	9/6/2016	9/6/2016	CRCES-I-068	261.00	Removed brass hose bib inline w/ sink	2/3/2017	CRCES-I-081	4.81
Room 2	Sink	7/13/2016	CRCES-I-015	7.29											
Room 2	Fountain	7/13/2016	CRCES-I-016	7.40											
East wing North End Girls Restroom (East Fixture)	Sink	7/13/2016	CRCES-I-017	2.32											
East wing North End Girls Restroom (West Fixture)	Sink	7/13/2016	CRCES-I-018	2.71											
East wing North End Boys Restroom (West Fixture)	Sink	7/13/2016	CRCES-I-019	1.01											
East wind North End Boys Restroom (East Fixture)	Sink	7/13/2016	CRCES-I-020	1.06											
Room 1	Sink	7/13/2016	CRCES-I-021	7.23											
East wing North End	Fountain	7/13/2016	CRCES-I-022	2.28											
Kitchen - Food only sink	Sink	7/13/2016	CRCES-I-023	3.83											
Kitchen Handwash sink	Sink	7/13/2016	CRCES-I-024	3.46											
Main Entry	Fountain	7/13/2016	CRCES-I-025	1.41											
Health Room	Sink	7/13/2016	CRCES-I-026	3.50											
Health Room Restroom	Sink	7/13/2016	CRCES-I-027	1.08											
Center wing North End Girls Restroom (South Fixture)	Sink	7/13/2016	CRCES-I-028	2.94											
Center Wing North End Girls Restroom (North Fixture)	Sink	7/13/2016	CRCES-I-029	1.48											
Room 9A	Sink	7/13/2016	CRCES-I-030	10.30											
Center Wing Corridor	Fountain	7/13/2016	CRCES-I-031	4.20											
Center Wing North End Boys Restroom (South Fixture)	Sink	7/13/2016	CRCES-I-032	12.80											
Center wing North end Boys Restroom (North Fixture)	Sink	7/13/2016	CRCES-I-033	4.73											
Room 10	Sink	7/13/2016	CRCES-I-034	7.57											
Room 10	Fountain	7/13/2016	CRCES-I-035	2.56											
Room 11	Fountain	7/13/2016	CRCES-I-036	1.11											
Room 11	Sink	7/13/2016	CRCES-I-037	4.04											
Room 12	Sink	7/13/2016	CRCES-I-038	8.22											
Room 12	Fountain	7/13/2016	CRCES-I-039	2.96											
Room 13 Restroom	Sink	7/13/2016	CRCES-I-040	4.93											
Room 13	Fountain	7/13/2016	CRCES-I-041	2.31											
Room 13	Sink	7/13/2016	CRCES-I-042	8.10											
Room 14	Sink	7/13/2016	CRCES-I-043	12.70											
Room 14	Fountain	7/13/2016	CRCES-I-044	1.29											
Room 14 Restroom	Sink	7/13/2016	CRCES-I-045	4.52											
Lower level Team Restroom	Sink	7/13/2016	CRCES-I-046	4.23											
Staff Lounge lower level	Sink	7/13/2016	CRCES-I-047	1.44											
Staff Lounge lower level	Insta-Hot	7/13/2016	CRCES-I-048	2.99											
Staff Lounge lower level Restroom	Sink	7/13/2016	CRCES-I-049	1.68											
West wing at entry	Fountain	7/13/2016	CRCES-I-050	4.07											
West wing Boys Restroom (North Fixture)	Sink	7/13/2016	CRCES-I-051	6.32											
West wing Boys Restroom (South Fixture)	Sink	7/13/2016	CRCES-I-052	3.99											
West Wing Girls Restroom (South Fixture)	Sink	7/13/2016	CRCES-I-053	8.10											
West Wing Girls Restroom (North Fixture)	Sink	7/13/2016	CRCES-I-054	4.57											
Room 15	Fountain	7/13/2016	CRCES-I-055	4.90											
Room 15	Sink	7/13/2016	CRCES-I-056	7.37											

Using EPA's water sampling method for schools, action level is >20 parts per billion (ppb). Samples that tested above the action level are highlighted.

Eugene School District 4J
Water Quality: Lead Testing Results

Eugene School District 4J - Location	Fixture Type	First Draw			Flushed Draw			New Fixture First Draw				Follow Up - New Fixture Draw			
		Date Sampled	Sample ID #	Result (ppb)	Date Sampled	Sample ID #	Result (ppb)	Fixture Replaced	Date Sampled	Sample ID #	Result (ppb)	Additional Action	Date Sampled	Sample ID #	Result (ppb)
Camas Ridge Community School															
Room 16	Fountain	7/13/2016	CRCES-I-057	2.57											
Room 16	Sink	7/13/2016	CRCES-I-058	2.57											
Room 17	Fountain	7/13/2016	CRCES-I-059	8.44											
Room 17	Sink	7/13/2016	CRCES-I-060	13.10											
Room 18	Fountain	7/13/2016	CRCES-I-061	14.80											
Room 18	Sink	7/13/2016	CRCES-I-062	5.92											
West wing South End Girls Restroom	Sink	7/13/2016	CRCES-I-063	3.20											
West wing South End Boys Restroom	Sink	7/13/2016	CRCES-I-064	3.97											
Library	Sink	9/6/2016	CRCES-I-067	28.10	9/19/2016	CRCES-F-076	2.61	10/13/2016	10/20/2016	CRCES-I-078	20.70	Replaced angle stops & nipples	2/3/2017	CRCES-I-080	1.85
Room #4	Fountain	9/6/2016	CRCES-I-069	81.10	9/19/2016	CRCES-F-077	ND	10/13/2016	10/20/2016	CRCES-I-079	1.47				
Exterior - Outside Room 11	Fountain	9/6/2016	CRCES-I-071	7.68											
Basement, Staff Restroom	Sink	9/6/2016	CRCES-I-072	4.08											
Basement, Staff Lounge	Sink	9/6/2016	CRCES-I-073	2.99											
Basement, Staff Lounge	Insta-Hot	9/6/2016	CRCES-I-074	ND											
Basement, North Restroom	Sink	9/6/2016	CRCES-I-075	3.57											

Using EPA's water sampling method for schools, action level is >20 parts per billion (ppb). Samples that tested above the action level are highlighted.

Report Date: 2/27/2017