

Eugene School District 4J
Water Quality: Lead Testing Results

Eugene School District 4J - Location			First Draw			Flushed Draw			New Fixture First Draw				Follow Up - New Fixture Draw					
Fixture Use	Fixture Type	Date Sampled	Sample ID #	Result (ppb)	Date Sampled	Sample ID #	Result (ppb)	Fixture Replaced	Date Sampled	Sample ID #	Result (ppb)	Additional Action	Date Flushed	Date Sampled	Date Received	Sample ID #	Result (ppb)	
McCornack Elementary School																		
Cafeteria	Drinking Fountain	Fountain	7/12/16	MCES-I-001	4.16													
Kitchen Dish Sink	Food Preparation	Sink	7/12/16	MCES-I-002	2.31													
Kitchen Produce Sink	Food Preparation	Sink	7/12/16	MCES-I-003	10.90													
Kitchen Hand Wash Sink	Food Preparation	Sink	7/12/16	MCES-I-004	4.67													
Kitchen Restroom	Food Preparation	Sink	7/12/16	MCES-I-005	2.06													
Boys Restroom South Sink	Other Human Consumption	Sink	7/12/16	MCES-I-006	0.30													
Boys Restroom North Sink	Other Human Consumption	Sink	7/12/16	MCES-I-007	0.42													
Girls Restroom South Sink	Other Human Consumption	Sink	7/12/16	MCES-I-008	0.89													
Girls Restroom North Sink	Other Human Consumption	Sink	7/12/16	MCES-I-009	0.54													
Gym Cafeteria Hallway	Drinking Fountain	Fountain	7/12/16	MCES-I-010	3.26													
Nurses Offices	Other Human Consumption	Sink	7/12/16	MCES-I-011	1.44													
Nurses Office Restroom	Other Human Consumption	Sink	7/12/16	MCES-I-012	3.78													
Men's Staff Restroom	Other Human Consumption	Sink	7/12/16	MCES-I-013	0.53													
Women's Staff Restroom	Other Human Consumption	Sink	7/12/16	MCES-I-014	1.32													
Staff Room	Other Human Consumption	Sink	7/12/16	MCES-I-015	0.43													
Staff Room	Drinking Fountain	Insta-Hot	7/12/16	MCES-I-016	ND													
Work Room (IMC)	Other Human Consumption	Sink	7/12/16	MCES-I-017	2.08													
Hallway outside of Library	Drinking Fountain	Fountain	7/12/16	MCES-I-018	5.29													
Library	Other Human Consumption	Sink	7/12/16	MCES-I-019	2.00													
Computer Lab	Other Human Consumption	Sink	7/12/16	MCES-I-020	35.50	8/30/16	MCES-F-086	2.92	9/1/16	9/6/16	MCES-I-094	32.20	1. Cut out hose bib in line with feed to fixture. 2. Replaced 3" Valve Serving Location	1. 10/31/2016 2. 2/9/2017	1. 11/3/2016 2. 2/10/2017	1. 11/8/2016 2. 2/15/2017	1. MCES-I-100 2. MCES-I-105	1. 37.4 2. 5.62
Conference Room	Other Human Consumption	Sink	7/12/16	MCES-I-021	16.10													
Room 17/18 lobby	Other Human Consumption	Sink	7/12/16	MCES-I-022	1.36													
Room 17/18 lobby	Drinking Fountain	Fountain	7/12/16	MCES-I-023	0.21													
Room 17	Other Human Consumption	Sink	7/12/16	MCES-I-024	0.88													
Room 17	Drinking Fountain	Fountain	7/12/16	MCES-I-025	ND													
Boys Restroom North Sink	Other Human Consumption	Sink	7/12/16	MCES-I-026	1.23													
Boys Restroom Center Sink	Other Human Consumption	Sink	7/12/16	MCES-I-027	0.94													
Boys Restroom South Sink	Other Human Consumption	Sink	7/12/16	MCES-I-028	0.93													
Girls Restroom North Sink	Other Human Consumption	Sink	7/12/16	MCES-I-029	1.09													
Girls Restroom Center Sink	Other Human Consumption	Sink	7/12/16	MCES-I-030	0.79													
Girls Restroom South Sink	Other Human Consumption	Sink	7/12/16	MCES-I-031	0.88													
Room 18	Other Human Consumption	Sink	7/12/16	MCES-I-032	3.36													
Room 18	Drinking Fountain	Fountain	7/12/16	MCES-I-033	0.28													
Room 9-16 Wing Boys Restroom East Sink	Other Human Consumption	Sink	7/12/16	MCES-I-034	6.77													
Room 9-16 Wing Boys Restroom West Sink	Other Human Consumption	Sink	7/12/16	MCES-I-035	5.00													
Room 9-16 Wing Girls Restroom East Sink	Other Human Consumption	Sink	7/12/16	MCES-I-036	3.94													
Room 9-16 Wing Girls Restroom West Sink	Other Human Consumption	Sink	7/12/16	MCES-I-037	4.93													
Room 9-16 Men's Staff Restroom	Other Human Consumption	Sink	7/12/16	MCES-I-038	21.80	8/30/16	MCES-F-087	2.74	9/1/16	9/6/16	MCES-I-095	7.65						
Room 9-16 Women's Staff Restroom	Other Human Consumption	Sink	7/12/16	MCES-I-039	5.08	8/30/16	MCES-F-088	ND	9/1/16	9/6/16	MCES-I-096	2.39						
Room 9	Other Human Consumption	Sink	7/12/16	MCES-I-040	35.80	8/30/16	MCES-F-089	ND	9/1/16	9/6/16	MCES-I-097	2.39						
Room 9	Drinking Fountain	Fountain	7/12/16	MCES-I-041	2.78													
Room 10	Other Human Consumption	Sink	7/12/16	MCES-I-042	42.00	8/30/16	MCES-F-090	ND	9/1/16	9/6/16	MCES-I-098	28.00	1. Cut out hose bib in line with feed to fixture. 2. Replaced 3" Valve Serving Location	1. 10/31/2016 2. 2/9/2017	1. 11/1/2016 2. 2/10/2017	1. 11/8/2016 2. 2/15/2017	1. MCES-I-101 2. MCES-I-106	6.94 2. 19.70
Room 10	Drinking Fountain	Fountain	7/12/16	MCES-I-043	25.40	8/30/16	MCES-F-089	2.41	9/1/16	9/6/16	MCES-I-097	51.10						
Room 22	Other Human Consumption	Sink	7/12/16	MCES-I-044	6.57													
Room 22	Drinking Fountain	Fountain	7/12/16	MCES-I-045	1.46													
Room 11	Other Human Consumption	Sink	7/12/16	MCES-I-046	5.57													
Room 11	Drinking Fountain	Fountain	7/12/16	MCES-I-047	6.38													
Room 12	Other Human Consumption	Sink	7/12/16	MCES-I-048	8.46													
Room 12	Drinking Fountain	Fountain	7/12/16	MCES-I-049	4.03													
Room 13	Other Human Consumption	Sink	7/12/16	MCES-I-050	3.90													
Room 13	Drinking Fountain	Fountain	7/12/16	MCES-I-051	8.93													
Room 14	Other Human Consumption	Sink	7/12/16	MCES-I-052	12.10													
Room 14	Drinking Fountain	Fountain	7/12/16	MCES-I-053	3.76													
Room 15	Other Human Consumption	Sink	7/12/16	MCES-I-054	47.90	8/30/16	MCES-F-091	2.78	9/1/16	9/6/16	MCES-I-099	35.20	1. Remv'd hose bib in-line w/ fixture. 2. Replaced 3" Valve Serving Location 3. 3/70 - Replaced T&S Faucet with Chicago 4. 8/8 - Replaced piping from angle stop to wall	1. 10/31/2016 2. 2/9/2017 3. 7/13/2017 4. 8/10/2017	1. 11/1/2016 2. 2/10/2017 3. 7/14/2017 4. 8/11/2017	1. 11/8/2016 2. 2/15/2017 3. 7/21/2017 4. 8/22/2017	1. MCES-I-103 2. MCES-I-107 3. MCES-I-108 4. MCES-I-109	1. 132.00 2. 29.50 3. 21.70 4. 2.89
Room 15	Drinking Fountain	Fountain	7/12/16	MCES-I-055	15.30													
Room 16	Other Human Consumption	Sink	7/12/16	MCES-I-056	14.80													
Room 16	Drinking Fountain	Fountain	7/12/16	MCES-I-057	10.10													
Room 8	Other Human Consumption	Sink	7/12/16	MCES-I-058	9.39													
Room 8	Drinking Fountain	Fountain	7/12/16	MCES-I-059	10.20													
Room 7	Other Human Consumption	Sink	7/12/16	MCES-I-060	20.00													
Room 7	Drinking Fountain	Fountain	7/12/16	MCES-I-061	6.58													
Room 1-8 Wing Boys Restroom East Sink	Other Human Consumption	Sink	7/12/16	MCES-I-062	2.08													
Room 1-8 Wing Boys Restroom West Sink	Other Human Consumption	Sink	7/12/16	MCES-I-063	1.48													
Room 6	Other Human Consumption	Sink	7/12/16	MCES-I-064	2.07													
Room 6	Drinking Fountain	Fountain	7/12/16	MCES-I-065	0.83													
Room 5	Other Human Consumption	Sink	7/12/16	MCES-I-066	1.91													
Room 5	Drinking Fountain	Fountain	7/12/16	MCES-I-067	10.10													
Room 4	Other Human Consumption	Sink	7/12/16	MCES-I-068	29.50	8/30/16	MCES-F-085	1.46	9/1/16	9/6/16	MCES-I-093	6.35						
Room 4	Drinking Fountain	Fountain	7/12/16	MCES-I-069	2.07													
Room 3	Other Human Consumption	Sink	7/12/16	MCES-I-070	19.80													
Room 3	Drinking Fountain	Fountain	7/12/16	MCES-I-071	2.60													
Room 1-8 Girls Restroom East Sink	Other Human Consumption	Sink	7/12/16	MCES-I-072	2.10													
Room 1-8 Girls Restroom West Sink	Other Human Consumption	Sink	7/12/16	MCES-I-073	1.60													
Room 2	Other Human Consumption	Sink	7/12/16	MCES-I-074	6.39													
Room 2	Drinking Fountain	Fountain	7/12/16	MCES-I-075	30.60	8/30/16	MCES-F-084	1.92	9/1/16	9/6/16	MCES-I-092	15.10	1. Cut out hose bib in line with feed to fixture	10/31/16	11/1/16	11/8/16	MCES-I-104	1.82
	Sample Numbers Not Used			MCES-I-076														
	Sample Numbers Not Used			MCES-I-077														
Custodial Office, East Wall	Other Human Consumption	Sink	7/28/16	MCES-I-078	1.58													
Custodial Storage, East Wall, Mop Basin	Non Reimbursable	Sink	7/28/16	MCES-I-079	0.74													
Kitchen Sprayer, Dish Pit, East Wall	Food Preparation	Sprayer	7/28/16	MCES-I-080	1.22													
Custodial Room, North Wall Mop Basin	Non Reimbursable	Sink	7/28/16	MCES-I-081	17.70													
Room 1	Drinking Fountain	Fountain	8/3/16	MCES-I-082	4.65													
Room 2	Sink	Sink	8/3/16	MCES-I-083	1.67													

Using EPA's water sampling method for schools, action level is 10-20 parts per billion (ppb). Samples that tested above the action level are highlighted.