

Eugene School District 4J
Water Quality: Lead Testing Results

Eugene School District 4J - Location			First Draw			Flushed Draw			New Fixture First Draw				Follow Up - New Fixture Draw					
Fixture Use	Fixture Type	Date Sampled	Sample ID #	Result (ppb)	Date Sampled	Sample ID #	Result (ppb)	Fixture Replaced	Date Sampled	Sample ID #	Result (ppb)	Additional Action	Date Flushed	Date Sampled	Date Received	Sample ID #	Result (ppb)	
Kennedy Middle School																		
I-2 East Wall Left	Other Human Consumption	Sink	7/11/16	KENMS-I-077	0.77													
I-2 East Wall Right	Other Human Consumption	Sink	7/11/16	KENMS-I-078	0.80													
I-Wing Science Storage	Other Human Consumption	Sink	7/11/16	KENMS-I-079	7.06													
I-Wing Science Storage	Other Human Consumption	Sink	7/11/16	KENMS-I-080	5.17													
I-Wing Staff Restroom	Other Human Consumption	Sink	7/11/16	KENMS-I-081	0.39													
I-3 West Wall	Other Human Consumption	Sink	7/11/16	KENMS-I-082	0.99													
I-3 West Wall	Other Human Consumption	Sink	7/11/16	KENMS-I-083	0.74													
I-Wing Main Area Lower Left	Drinking Fountain	Fountain	7/11/16	KENMS-I-084	ND													
I-Wing Main Area Upper Right	Drinking Fountain	Fountain	7/11/16	KENMS-I-085	0.21													
I-Wing Girls Restroom Left	Other Human Consumption	Sink	7/11/16	KENMS-I-086	2.61													
I-Wing Girls Restroom Right	Other Human Consumption	Sink	7/11/16	KENMS-I-087	1.40													
I-4 West Wall	Other Human Consumption	Sink	7/11/16	KENMS-I-088	1.11													
H-Wing Boys Restroom Left	Other Human Consumption	Sink	7/11/16	KENMS-I-089	2.23													
H-Wing Boys Restroom Right	Other Human Consumption	Sink	7/11/16	KENMS-I-090	1.71													
Room Adjacent to H-1	Other Human Consumption	Sink	7/11/16	KENMS-I-091	6.17													
Room Adjacent to H-5	Other Human Consumption	Sink	7/11/16	KENMS-I-092	2.90													
H-Wing Girls Restroom Left	Other Human Consumption	Sink	7/11/16	KENMS-I-093	3.26													
H-Wing Girls Restroom Right	Other Human Consumption	Sink	7/11/16	KENMS-I-094	1.82													
H-Wing Main Area / Locker Bays	Drinking Fountain	Fountain	7/11/16	KENMS-I-095	2.84													
Kitchen	Food Preparation	Sprayer	9/9/16	KENMS-I-096	1.63													
Kitchen Produce	Food Preparation	Sink	9/9/16	KENMS-I-097	6.58													
F1 Office	Drinking Fountain	Insta-Hot	9/9/16	KENMS-I-104	ND													
F1 Office	Other Human Consumption	Sink	9/9/16	KENMS-I-103	12.30	9/30/16	KENMS-I-125	1.61	10/13/16	10/20/16	KENMS-I-130	28.40	1. New Angle Stops and Nipples 2. Removed hot water from Mixing 3. Permanent Label Installed	1. 2/9/2017 2. 7/13/2017	1. 2/10/2017 2. 7/14/2017	1. 2/21/2017 2. 7/21/2017	1. KENMS-I-148 2. KENMS-I-157	1. 31.70 2. 31.40
I1 Demonstration Table	Other Human Consumption	Sink	9/9/16	KENMS-I-107	7.26													
I1 East Wall North	Other Human Consumption	Sink	9/9/16	KENMS-I-105	3.64													
I1 East Wall South	Other Human Consumption	Sink	9/9/16	KENMS-I-106	ND													
Room at Center of G3 Wing Right	Drinking Fountain	Insta-Hot	9/9/16	KENMS-I-115	4.35													
F5 Office	Other Human Consumption	Sink	10/20/16	KENMS-I-131	41.30	Sample not Taken	Sample not Taken	Sample not Taken	12/28/17	2/10/17	KENMS-I-149	490.00	1. Removed hot water from Mixing 2. Permanent Label Installed	7/13/17	7/14/17	7/21/17	KENMS-I-158	26.60
Custodial Utility Sink - Not sampled. No access																		
Total Samples Taken		172.00	Total Elevated on 1st Draw		104.00	Total Elevated on Flush Draw		23.00	Total Elevated on Final/Replacement Draw			23.00						22.00