

Eugene School District 4J
Water Quality: Lead Testing Results

Eugene School District 4J - Location	Fixture Use	Fixture Type	Date Sampled	First Draw	
				2020-21 Sample ID #	2021 Result (ppb)
Bailey Hill					
Hallway Outside Room 11 - Drinking Fountain	Drinking Fountain	Fountain	9/8/2021	20800000-012DW	0.95
Hallway Outside Room 11 - Bottle Filler	Other Human Consumption	Bottle Filler	9/8/2021	20800000-074WB	0.96
Room 12	Other Human Consumption	Sink	6/2/2021	20800000-010CF	7.58
Room 12 East Restroom	Other Human Consumption	Sink	6/2/2021	20800000-008BF	2.37
Room 12 West Restroom	Other Human Consumption	Sink	6/2/2021	20800000-011BF	2.37
Room 11 West Restroom	Other Human Consumption	Sink	6/2/2021	20800000-015BF	12.00
North Hall Men's Restroom (South)	Other Human Consumption	Sink	6/2/2021	20800000-006BF	5.20
North Hall Women's Restroom (North)	Other Human Consumption	Sink	6/2/2021	20800000-003BF	10.60
Room 13	Other Human Consumption	Sink	6/2/2021	20800000-001CF	8.39
Room 13	Drinking Fountain	Fountain	6/2/2021	20800000-035DW	8.32
Health Center	Other Human Consumption	Sink	6/2/2021	20800000-017NS	10.40
Staff Room	Other Human Consumption	Sink	6/2/2021	20800000-032SF	2.45
Staff Room - Sink Sprayer	Other Human Consumption	Sprayer	6/2/2021	20800000-028OT	2.86
Instructional Materials Center	Other Human Consumption	Sink	6/2/2021	20800000-028OT	2.86
Hallway outside Multi Purpose Room	Drinking Fountain	Fountain	6/2/2021	20800000-027DW	4.92
Hallway outside Multi Purpose Room	Drinking Fountain	Fountain	6/2/2021	20800000-074SF	0.60
Main Hall Women's Restroom	Other Human Consumption	Sink	6/2/2021	20800000-030BF	3.83
Main Hall Men's Restroom	Other Human Consumption	Sink	6/2/2021	20800000-031BF	1.90
Kitchen Handwash Sink	Food Preparation	Sink	6/2/2021	20800000-024KF	2.59
Kitchen Dish Sink - South Side	Food Preparation	Sprayer	6/2/2021	20800000-026KF	8.92
Kitchen Dish Sink - North Side	Food Preparation	Sink	6/2/2021	20800000-025KF	4.38
Kitchen - Ice Machine	Drinking Fountain	Ice Machine	6/2/2021	20800000-023IM	0.25
Library Storage	Other Human Consumption	Sink	6/2/2021	20800000-034SF	7.79
Room 9	Other Human Consumption	Sink	6/2/2021	20800000-037CF	2.13
Room 8	Other Human Consumption	Sink	6/2/2021	20800000-041CF	6.28
Room 7 South Restroom	Other Human Consumption	Sink	6/2/2021	20800000-046BF	10.30
Room 3 Boys Restroom	Other Human Consumption	Sink	6/2/2021	20800000-060BF	4.65
Room 3 Girls Restroom	Other Human Consumption	Sink	6/2/2021	20800000-057BF	4.94
Room 3 East entry	Drinking Fountain	Fountain	6/2/2021	20800000-048DW	8.36
Room 3 Southwest corner	Other Human Consumption	Sink	6/2/2021	20800000-049CF	4.13
Room 3 Southwest corner	Drinking Fountain	Fountain	6/2/2021	20800000-050DW	2.78
Room 1	Drinking Fountain	Fountain	6/2/2021	20800000-058DW	13.80
Room 1/2	Drinking Fountain	Fountain	6/2/2021	20800000-054DW	12.00
Room 2	Other Human Consumption	Sink	6/2/2021	20800000-051CF	10.90
Room 2	Drinking Fountain	Fountain	6/2/2021	20800000-052DW	3.53
Room 5	Other Human Consumption	Sink	6/2/2021	20800000-065CF	2.07
Room 5	Drinking Fountain	Fountain	6/2/2021	20800000-064DW	2.23
Room 5 - Sprayer	Other Human Consumption	Sprayer	6/2/2021	20800000-062OT	13.90
Room 4/5 Girls Restroom	Other Human Consumption	Sink	6/2/2021	20800000-070BF	7.43
East Wall Between Rooms 4/5	Drinking Fountain	Fountain	6/2/2021	20800000-071DW	6.82
Room 6 Southeast Corner	Other Human Consumption	Sink	6/2/2021	20800000-063CF	8.21
Room 4	Other Human Consumption	Sink	6/2/2021	20800000-069CF	5.36
Room 4	Drinking Fountain	Fountain	6/2/2021	20800000-068DW	3.99
Room 6	Drinking Fountain	Fountain	6/2/2021	20800000-061DW	7.20
Room 6 Boys Restroom	Other Human Consumption	Sink	6/2/2021	20800000-067BF	11.80
Fixture Types:					
DF= Drinking Fountain S= Sink IH= Instahot FR= Fridge HB= Hose Bib					

Using EPA's water sampling method for schools, action level is >15 parts per billion (ppb). Samples that tested above the action level are highlighted.

Eugene School District 4J
Water Quality: Lead Testing Results

Cell: A46

Comment: rummel_d dexter rummel:
Missing from 2021?