

Eugene School District 4J
Water Quality: Lead Testing Results

Eugene School District 4J - Location			First Draw			
Gilham Elementary School		Fixture Use	Fixture Type	Date Sampled	Sample ID#	2021-22 result (ppb)
Main entrance - Bottle Filler	Other Human Consumption	Bottle Filler	12/3/2021	20820600-051WB	ND	
Main entrance - Drinking Fountain	Drinking Fountain	Fountain	12/3/2021	20820600-052DW	ND	
D Center hallway Men's Restroom (left)	Other Human Consumption	Sink	12/3/2021	20820600-054BF	ND	
D Center hallway Men's Restroom (right)	Other Human Consumption	Sink	12/3/2021	20820600-053BF	0.53	
D Center hallway Women's Restroom (right)	Other Human Consumption	Sink	12/3/2021	20820600-073SF	12.50	
Unit D Center	Other Human Consumption	Sink	9/8/2021	20820600-067CF	10.60	
D1- (right)	Other Human Consumption	Sink	10/15/2021	20820600-057CF	2.71	
D1 (left)	Drinking Fountain	Fountain	9/8/2021	20820600-056DW	5.79	
D2 (left)	Drinking Fountain	Fountain	9/8/2021	20820600-059DW	2.10	
D2 (right)	Other Human Consumption	Sink	9/8/2021	20820600-060CF	5.36	
D3 (right)	Drinking Fountain	Fountain	9/8/2021	20820600-062DW	2.72	
D3 (left)	Other Human Consumption	Sink	9/8/2021	20820600-061CF	7.45	
D4 (right)	Drinking Fountain	Fountain	9/8/2021	20820600-066DW	3.72	
D4 (left)	Other Human Consumption	Sink	10/15/2021	20820600-065CF	5.83	
Girls Restroom by B118 (left)	Other Human Consumption	Sink	12/3/2021	20820600-104BF	0.66	
Girls Restroom by B118 (middle)	Other Human Consumption	Sink	12/3/2021	20820600-105BF	0.25	
Girls Restroom by B118 (right)	Other Human Consumption	Sink	12/3/2021	20820600-106BF	0.47	
Outside Girls Restroom (Lower)	Drinking Fountain	Fountain	12/3/2021	20820600-107DW	0.44	
Outside Girls Restroom (Upper)	Drinking Fountain	Fountain	12/3/2021	20820600-108DW	0.63	
Unit E Interior (Right) of door (Right)	Drinking Fountain	Fountain	12/3/2021	20820600-005DW	ND	
Unit E Restroom	Other Human Consumption	Sink	12/3/2021	20820600-004BF	0.23	
E4 (left)	Other Human Consumption	Sink	4/8/2022	20820600-001CF	0.93	
E4 (right)	Drinking Fountain	Fountain	12/3/2021	20820600-002DW	1.70	
E3 (left)	Drinking Fountain	Fountain	12/3/2021	20820600-008DW	1.21	
E3 (right)	Other Human Consumption	Sink	3/15/2022	20820600-007CF	1.97	
E2 (left)	Drinking Fountain	Fountain	12/3/2021	20820600-014DW	1.03	
E2 (right)	Other Human Consumption	Sink	3/15/2022	20820600-013CF	3.45	
E1 (left)	Drinking Fountain	Fountain	12/3/2021	20820600-012DW	2.43	
E1 (right)	Other Human Consumption	Sink	4/8/2022	20820600-011CF	1.05	
Unit E Center	Other Human Consumption	Sink	2/8/2022	20820600-009CF	11.60	
Unit F Interior (right) of door (Upper)	Drinking Fountain	Fountain	12/3/2021	20820600-032DW	ND	
Unit F Interior (right) of door (Lower)	Drinking Fountain	Fountain	12/3/2021	20820600-031DW	0.57	
Unit F Restroom	Other Human Consumption	Sink	12/3/2021	20820600-018BF	ND	
F4 (left)	Drinking Fountain	Fountain	12/3/2021	20820600-017DW	3.83	
F4 (right)	Drinking Fountain	Fountain	3/15/2022	20820600-016CF	3.33	
F3 (left)	Drinking Fountain	Fountain	12/3/2021	20820600-021DW	0.33	
F3 (right)	Other Human Consumption	Sink	3/15/2022	20820600-020CF	2.86	
F2 (left)	Drinking Fountain	Fountain	12/3/2021	20820600-024DW	0.83	
F2 (right)	Other Human Consumption	Sink	3/15/2022	20820600-023CF	1.25	
F1 (left)	Other Human Consumption	Sink	4/8/2022	20820600-034CF	0.73	
F1 (right)	Drinking Fountain	Fountain	12/3/2021	20820600-033DW	0.91	
Unit F Center	Other Human Consumption	Sink	3/15/2022	20820600-019CF	2.30	
Boys Restroom by A101 (left)	Other Human Consumption	Sink	12/3/2021	20820600-140BF	0.22	
Boys Restroom by A101 (middle)	Other Human Consumption	Sink	12/3/2021	20820600-141BF	ND	
Boys Restroom by A101 (right)	Other Human Consumption	Sink	12/3/2021	20820600-142BF	ND	
Girls Restroom by A101 (left)	Other Human Consumption	Sink	12/3/2021	20820600-136BF	ND	
Girls Restroom by A101 (middle)	Other Human Consumption	Sink	12/3/2021	20820600-137BF	0.21	
Girls Restroom By a101 (right)	Other Human Consumption	Sink	12/3/2021	20820600-138BF	1.00	
Hallway across from A101 (Lower)	Drinking Fountain	Fountain	12/3/2021	20820600-134DW	ND	
Hallway across from A101 (Upper)	Drinking Fountain	Bottle Filler	12/3/2021	20820600-135WB	ND	
Cafeteria - North wall (Lower)	Drinking Fountain	Fountain	12/3/2021	20820600-119DW	0.27	
Cafeteria - North wall (Upper)	Drinking Fountain	Fountain	12/3/2021	20820600-120DW	0.81	
Kitchen West Wall Sprayer	Food Preparation	Sprayer	12/3/2021	20820600-122KF	0.26	
Kitchen Northwest Corner	Food Preparation	Sink	12/3/2021	20820600-131KF	1.94	
Kitchen Center Island Large Prep (right)	Food Preparation	Sink	12/3/2021	20820600-129KF	3.27	
Kitchen Center Island Large Prep (Left)	Food Preparation	Sink	12/3/2021	20820600-128KF	7.05	
Kitchen Restroom	Food Preparation	Sink	12/3/2021	20820600-130BF	ND	
Kitchen Basin Sprayer	Food Preparation	Sprayer	12/3/2021	20820600-127KF	13.40	
Kitchen Produce Sprayer	Food Preparation	Sprayer	12/3/2021	20820600-126KF	0.33	
Kitchen By Service window (left)	Food Preparation	Sink	12/3/2021	20820600-125KF	4.60	
Kitchen by Service Window (right)	Food Preparation	Sink	12/3/2021	20820600-123KF	0.88	
Room B101	Other Human Consumption	Sink	12/3/2021	20820600-118CF	0.48	
Room B101	Drinking Fountain	Fountain	12/3/2021	20820600-117DW	4.84	
Room B102	Drinking Fountain	Fountain	12/3/2021	20820600-115DW	3.26	

Using EPA's water sampling method for schools, action level is >15 parts per billion (ppb). Samples that tested above the action level are highlighted.

Eugene School District 4J
Water Quality: Lead Testing Results

Eugene School District 4J - Location			First Draw		
Gilham Elementary School	Fixture Use	Fixture Type	Date Sampled	Sample ID#	2021-22 result (ppb)
Room B102	Other Human Consumption	Sink	12/3/2021	20820600-116CF	0.62
Room B103	Drinking Fountain	Fountain	12/3/2021	20820600-110DW	3.90
Room B103	Other Human Consumption	Sink	12/3/2021	20820600-111CF	0.87
Room B104	Other Human Consumption	Sink	12/3/2021	20820600-113CF	0.65
Room B107	Drinking Fountain	Fountain	12/3/2021	20820600-101DW	2.01
Room B107	Other Human Consumption	Sink	12/3/2021	20820600-102CF	3.43
Room B109	Other Human Consumption	Sink	12/3/2021	20820600-098CF	0.45
Room B109	Drinking Fountain	Fountain	12/3/2021	20820600-097DW	4.58
Room B110	Drinking Fountain	Fountain	12/3/2021	20820600-086DW	1.17
Room B110	Other Human Consumption	Sink	12/3/2021	20820600-087CF	1.02
Room B111	Other Human Consumption	Sink	12/3/2021	20820600-089CF	0.78
Room B111	Drinking Fountain	Fountain	12/3/2021	20820600-088DW	2.27
Room B112	Other Human Consumption	Sink	12/3/2021	20820600-028CF	0.81
Room B112	Drinking Fountain	Fountain	12/3/2021	20820600-027DW	0.28
Room B113	Drinking Fountain	Fountain	12/3/2021	20820600-029DW	2.52
Room B113	Other Human Consumption	Sink	12/3/2021	20820600-030CF	0.62
Hallway across from B109 (Lower)	Drinking Fountain	Fountain	12/3/2021	20820600-092DW	0.75
Hallway across from B109 (Upper)	Drinking Fountain	Fountain	12/3/2021	20820600-093DW	0.36
Boys Restroom next to B117 (left)	Other Human Consumption	Sink	12/3/2021	20820600-096BF	0.34
Boys Restroom next to B117 (middle)	Other Human Consumption	Sink	12/3/2021	20820600-095BF	0.30
Boys Restroom next to B117 (right)	Other Human Consumption	Sink	12/3/2021	20820600-094BF	0.31
Room C121	Other Human Consumption	Sink	12/3/2021	20820600-075CF	3.79
Room C121	Drinking Fountain	Fountain	12/3/2021	20820600-076DW	6.56
Library Office	Other Human Consumption	Sink	2/8/2022	20820600-081SF	4.52
Room C106	Other Human Consumption	Sink	12/3/2021	20820600-084CF	4.27
Room C109	Drinking Fountain	Fountain	12/3/2021	20820600-083DW	10.70
Room C109	Other Human Consumption	Sink	12/3/2021	20820600-082CF	3.51
Room C112	Other Human Consumption	Sink	12/3/2021	20820600-077SF	1.08
Staff Room	Other Human Consumption	Sink	12/3/2021	20820600-045SF	0.83
Staff Room	Drinking Fountain	Insta-Hot	12/3/2021	20820600-044OT	ND
Staff Room Men's Restroom	Other Human Consumption	Sink	12/3/2021	20820600-046BF	0.51
Staff Room Women's Restroom	Other Human Consumption	Sink	12/3/2021	20820600-047BF	0.25
C120 First Aid Room	Other Human Consumption	Sink	12/3/2021	20820600-048NS	2.53
Women's Restroom near D Pod (L)	Other Human Consumption	Sink	12/3/2021	20820600-069BF	0.45
B104	Drinking Fountain	Fountain	12/3/2021	20820600-112DW	0.27
A119 (Music Room)	Other Human Consumption	Sink	12/3/2021	20820600-144CF	ND
Staff Room Refrigerator - In Door	Drinking Fountain	Water D.	12/3/2021	20820600-043OT	ND
Staff Room Refrigerator - In Door	Drinking Fountain	Ice Machine	12/3/2021	20820600-145OT	ND
Room C122 Learning Center	Drinking Fountain	Fountain	12/3/2021	20820600-079DW	1.24
Room C122 Learning Center	Other Human Consumption	Sink	3/15/2022	20820600-078CF	4.11
Room C124 Multi-Purpose Room Left	Other Human Consumption	Sink	3/15/2022	20820600-040CF	1.20
Room C124 Multi-Purpose Room Left	Drinking Fountain	Fountain	12/3/2021	20820600-039DW	0.98
Room C124 Multi-Purpose Room Right	Other Human Consumption	Sink	3/15/2022	20820600-041CF	0.83
Room C124 Multi-Purpose Room Utility	Other Human Consumption	Sink	12/3/2021	20820600-085CF	ND
Room B116A - Single Occ Restroom	Other Human Consumption	Sink	12/3/2021	20820600-145OT	ND
PE Coaches Office Bathroom	Other Human Consumption	Sink	12/3/2021	20820600-121BF	0.20
B128 Community Room	Other Human Consumption	Sink	3/15/2022	20820600-071CF	2.08
B128 Community Room	Drinking Fountain	Fountain	12/3/2021	20820600-072DW	2.16
Women's Restroom near D Pod (R)	Other Human Consumption	Sink	12/3/2021	20820600-068BF	0.31
Unit E Interior (Right) of door (Left)	Drinking Fountain	Fountain	12/3/2021	20820600-006DW	ND
Nurse Office Bathroom	Other Human Consumption	Sink	12/3/2021	20820600-049BF	0.35
Fixture Types: DF= Drinking Fountain S= Sink IH= Instahot FR= Fridge HB= Hose Bib					

Using EPA's water sampling method for schools, action level is >15 parts per billion (ppb). Samples that tested above the action level are highlighted.